

# T E S T   C E R T I F I C A T E

**Product:** Parquet Baltic Floor Laquered  
(Multilayer Parquet Element, 3 layers, 14 mm thick)

**Customer:** Baltic Wood S.A.  
ul. Fabryczna 6A  
PL- 38200 JASLO  
Poland

**Order:** Determination of properties according to EN 14342

**Test methods:** Determination of the formaldehyde emission according to EN 717-1  
Determination of the PCP content according to CEN/TR 14823 in connection with  
the institute standard ihd-W 409

**Basics:** 276025

**Test results:**

Property	Result	Declaration according to EN 14342
Formaldehyde emission according to EN 717-1	0,01 ppm	Class E1
Content of PCP	unverifiable	PCP free

Dresden, 13.04.2006



Head of laboratory





Engineer in charge