

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-23-05-24-

**Products:** Engineered Wood Flooring with different UV-lacquered wood species in the top layer;  
core and back layer: Eucalyptus;  
dimensions: length (300 - 3000) mm x width (70 - 300) mm x thickness (8 - 22) mm

**Producer:**

**Order:** Testing of selected properties according to EN 14342:2013 for CE-labelling

**Test report:** 2708003/2

**Test results:** *The above mentioned Engineered Wood Flooring can be classified regarding to both properties according to EN 14342:2013 (CE-labelling) as follows:*

Property	Results	Declaration according to EN 14342:2013
Formaldehyde emission according to EN 717-1:2004:10	< LOD (96 h)	Class E1
Content of PCP according to CEN/TR 14823:2004	3,8 mg/kg	PCP ≤ 5 x 10 <sup>-6n</sup>

LOD = Limit of Detection

Dresden, 24/05/2023



Head of laboratory

Engineer in charge